

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sheshu Ram Chauhan

(Name of Officers with designation) from Water Testing Lab, Jal Shakti Vibhag, Una No 1, PHED

inspected the J.S. Wisdom World School, Una (H.P.)

(Name & Address of the school) on 06/05/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. WTL/26-35 dated 02/05/2026

of Water Testing Lab, Jal Shakti Vibhag No. 1 PHED Lab certified that

the J.S. Wisdom World School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 06 months from issue date

Assistant Engineer  
Jal Shakti Vibhag  
Sub Divn. No. I, Una

Signature with Seal: .....

Name : .....

Designation : .....

Name & Address of the Office / Department : .....

To J.S. Wisdom World

School, Una

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Note :-> The above mentioned water samples is found satisfactory (ie. the results are within specified limits) as per 67 | Page BIS standard in relation to the parameters mentioned in the report attached.

(SHIKHA THAKUR)

Assistant chemist  
Water Testing Lab, Una (HP)



HIMACHAL PRADESH  
WATER TESTING LABORATORY  
JAL SHAKTI VIBHAG, UNA NO.1

TC - 12017

TEST REPORT

ULR-TC121072500000035 F

Test Report No: WTL/ 26-25

Issue Date: 02/05/2026

Name & Address of Customer: J.S. Wisdom World School R/O Friends Colony  
 Sampling Method: N.A. Condition of Sample When Received: OK  
 Sample Description: Water Name of Source/Scheme: —  
 Sample Quantity: 3 Litre Name of Panchayat: Una (Aneya Nagar)  
 Collected on: 29-04-2026 Name of Habitation: J.S. Wisdom World School  
 Received on: 29-04-2026 Name of Village: Una  
 Test Start Date: 29-04-2026 Type of Source: Tap Water  
 Test End Date: 02-05-2026 Environmental Conditions: Temperature: 25±2°C Humidity: 45±10%

Sr. No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible limit in the absence of Alternate Source
<b>Physical Parameters</b>					
1.	Turbidity, NTU, Max	IS:3025(Part-10): 2023	2.10 NTU	1 NTU	5 NTU
2.	Colour, Hazen units, Max	IS:3025(Part-4): 2021	BDL(DL=5)	5	15
3.	Odour	IS-3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable
4.	Taste	IS-3025 (Part 8): 2023	Agreeable	Agreeable	Agreeable
5.	pH value	IS:3025(Part-11): 2022	7.43	6.5-8.5	No relaxation
6.	Total Dissolved Solids mg/l, Max	IS:3025(Part-16): 2023	302 mg/l	500 mg/l	2000 mg/l
<b>Chemical Parameters</b>					
7.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/l, Max	IS:3025 (Part-23): 2023	220 mg/l	200 mg/l	600 mg/l
8.	Chloride (as Cl), mg/l, Max	IS:3025 (Part-32): 2025	18 mg/l	250 mg/l	1000 mg/l
9.	Total Hardness (as CaCO <sub>3</sub> ), mg/l, Max	IS:3025 (Part-21): 2023	206 mg/l	200 mg/l	600 mg/l
10.	Calcium (as Ca), mg/l, Max	IS:3025 (Part-40): 2024	61.72 mg/l	75 mg/l	200 mg/l
11.	Magnesium (as Mg), mg/l, Max	IS:3025 (Part-46): 2023	1264 mg/l	30 mg/l	100 mg/l

Remarks (if any) BDL= Below Detection Limit; DL= Detection Limit; NP= Not Performed

Note:

- This report should not be produced partly or full without approval of signatory authority for legal purpose
- The results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 5 days from the date of issue of report.

Reviewed By

Water Testing Laboratory, Una No.1

Authorized Signatory

Mrs. Shikha Thakur

Water Testing Laboratory, Una No.1

**HIMACHAL PRADESH  
WATER TESTING LABORATORY  
JAL SHAKTI VIBHAG, UNA No.1**

**TEST REPORT**

Issue Date:- 02/05/2026

Test Report No: WTL/26-35

Sr. No.	Test	Result	Requirements As per IS 10500:2012	
			Acceptable Limit	Permissible limit in the absence of Alternate Source
<b>Physical Parameters</b>				
1.	Temperature (°C)	25.9°C	-----	-----
<b>Chemical Parameters</b>				
2.	Nitrate (as NO <sub>3</sub> ), mg/l, Max	—	45 mg/l Max	No relaxation
3.	Fluoride (as F), mg/l, Max	—	1.0 mg/l Max	1.5 mg/l Max
4.	Sulphate (as SO <sub>4</sub> ), mg/l, Max	—	200 mg/l Max	400 mg/l Max
5.	Ammonia (as total ammonia -N), mg/l, Max	—	0.5 mg/l Max	No relaxation
6.	Iron (as Fe), mg/l, Max	—	1.0 mg/l Max	No relaxation
7.	Manganese (as Mn), mg/l, Max	—	0.1 mg/l Max	0.3 mg/l Max
8.	Total Arsenic (as As), mg/l, Max	—	0.01 mg/l Max	No relaxation
9.	Free Residual Chlorine, mg/l, Min	nil	0.2 mg/l Min	1.0 mg/l Min

Remarks (if any) BDL= Below Detection Limit; DL= Detection Limit



Authorized Signatory  
Mrs. Shikha Thakur  
Water Testing Laboratory, Una No.1



HIMACHAL PRADESH  
WATER TESTING LABORATORY  
JAL SHAKTI VIBHAG, UNA NO.1

TEST REPORT

TC - 12017

ULR-TC1210725000000 035F

Issue Date:- 02/05/26

Test Report No: WTL/26-35

Name & Address of Customer: J.S. blissdom world school R/o friends colony

Condition of Sample When Received: OK

Sampling Method: M.A.

Name of Source/Scheme: —

Sample Description: Water

Name of Panchayat: Una (Asya Negas)

Sample Quantity: 500 ml

Name of Habitation: J.S. blissdom world school

Collected on: 29-04-2016

Name of Village: Una

Received on: 29-04-2016

Type of Source: Tap Water

Test Start Date: 29-04-2016

Environmental Conditions: Temperature:  $25 \pm 2^\circ\text{C}$  Humidity:  $45 \pm 10\%$

Test End Date: 02/05/26

Sr. No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible limit in the absence of Alternate Source
<b>Bacteriological Parameters</b>					
1.	Total Coliform Bacteria (Shall not be detectable in any 100ml sample)	IS 15185:2016	Absent	Nil	Nil
2.	E. Coli (Shall not be detectable in any 100ml sample)	IS 15185:2016	Absent	Nil	Nil

Reviewed By [Signature]  
Water Testing Laboratory, Una No.1

[Signature]  
Authorized Signatory  
Ms. Rumita Chandel  
Water Testing Laboratory, Una No.1